

Paron - Owensville Water Authority

2015 Annual Drinking Water Quality Report

We're pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our goal is to provide you with a safe and dependable supply of drinking water, and we want you to understand, and be involved in, the efforts we make to continually improve the water treatment process and protect our water resources.

Where Does Our Drinking Water Come From?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. We purchase treated water from North Garland County Regional Water District whose source is surface water from Lake Ouachita, and treated surface water from Hot Springs, whose sources are Lakes Hamilton, Ricks, Dillon and Sanders. We also bought water from Hot Springs Village whose source is surface water from Lake Lago and Middle Fork Saline River, and we purchased water from Central Arkansas Water (CAW), whose source is surface water from, Lake Winona and Lake Maumelle.

How Safe Is The Source Of Our Drinking Water?

The Arkansas Department of Health has completed a Source Water Vulnerability Assessment for North Garland County Regional Water District. The assessment summarizes the potential for contamination of our source of drinking water and can be used as a basis for developing a source water protection plan. Based on the various criteria of the assessment, our water source has been determined to have a low susceptibility to contamination. You may request a summary of the Source Water Vulnerability Assessment from our office.

What Contaminants Can Be In Our Drinking Water?

As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; Inorganic contaminants such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; Pesticides and herbicides which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; Organic chemical contaminants including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; Radioactive contaminants which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to assure tap water is safe to drink, EPA has regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Am I at Risk?

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. However, some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from small amounts of contamination. These people should seek advice about drinking water from their health care providers. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791. In addition, EPA/CDC guidelines on appropriate means to lessen the risk of infection by microbiological contaminants are also available from the Safe Drinking Water Hotline.

What is Cryptosporidium?

Cryptosporidium is a microbial pathogen found in surface water throughout the U.S. It lives and reproduces only with the host. In the environment, *Cryptosporidium* exists as a thick walled oocyst, containing four organisms. Monitoring by Central Arkansas Water in 2015 indicated no presence of these organisms in their Lake Maumelle, Lake Winona, or Jackson Reservoir water sources, in addition, monitoring by Hot Springs Utilities in 2015 indicated no presence of these organisms in their Lake Ricks, Lake Hamilton, or Lake Dillon water sources. It is important to know that although filtration removes *Cryptosporidium*, the most commonly used filtration methods cannot guarantee 100 percent removal. Ingestion of *Cryptosporidium* may cause cryptosporidiosis, an abdominal infection. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks. However, immuno-compromised people are at greater risk of developing life threatening illness. We encourage immuno-compromised individuals to consult their doctor regarding appropriate precautions to take to avoid infection. *Cryptosporidium* must be ingested to cause disease, and it may be spread through means other than drinking water.

Lead and Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components.

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

How Can I Learn More About Our Drinking Water?

If you have any questions about this report or concerning your water utility, please contact Jamie Mullins, Office Manager, at 501-594-5000. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the third Thursday of each month at 6:30 PM at Paron Community Center, 24000 Hwy 9 in Paron.

TEST RESULTS

We, Central Arkansas Water, City of Hot Springs, Hot Springs Village, and North Garland County Regional Water District routinely monitor for constituents in your drinking water according to Federal and State laws. The test results table shows the results of our monitoring for the period of January 1st to December 31st, 2015. In the table you might find terms and abbreviations you are not familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - unenforceable public health goal; the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Nephelometric Turbidity Unit (NTU) - a unit of measurement for the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Parts per billion (ppb) - a unit of measurement for detected levels of contaminants in drinking water. One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per million (ppm) - a unit of measurement for detected levels of contaminants in drinking water. One part per million corresponds to one minute in two years or a single penny in \$10,000.

| MICROBIOLOGICAL CONTAMINANTS | | | | | | |
|---|---------------|--|---------|---------------------------|--|--------------------------------------|
| Contaminant | Violation Y/N | Level Detected | Unit | MCLG (Public Health Goal) | MCL (Allowable Level) | Major Sources in Drinking Water |
| Total Coliform Bacteria (Paron Owensville) | N | None | Present | 0 | 1 positive sample per month | Naturally present in the environment |
| TURBIDITY | | | | | | |
| Contaminant | Violation Y/N | Level Detected | Unit | MCLG (Public Health Goal) | MCL (Allowable Level) | Major Sources in Drinking Water |
| Turbidity (Paron-Owensville) | N | Highest yearly sample result: 0.35 Lowest monthly % of samples meeting the turbidity limit: 98.4% | NTU | NA | Any measurement in excess of 1 NTU constitutes a violation | Soil runoff |
| Turbidity (No. Garland Co.) | N | Highest yearly sample result: 0.07 Lowest monthly % of samples meeting the turbidity limit: 100% | | | | |
| Turbidity (CAW) | N | Highest yearly sample result: 0.21 Lowest monthly % of samples meeting the turbidity limit: 100% | | | | |
| Turbidity (Hot Springs Village) | N | Highest yearly sample result: 0.08 Lowest monthly % of samples meeting the turbidity limit: 100% | | | | |
| Turbidity (Hot Springs) | N | Highest yearly sample result: 0.90 Lowest monthly % of samples meeting the turbidity limit: 100% | | | | |
| ♦ Turbidity is a measurement of the cloudiness of water. Paron- Owensville, North Garland County, Hot Springs Village, and CAW monitor it because it is a good indicator of the effectiveness of their filtration system. | | | | | | |

| INORGANIC CONTAMINANTS | | | | | | |
|--|-------------------------------------|---|------------------------------|--|--|---|
| Contaminant | Violation Y/N | Level Detected | Unit | MCLG (Public Health Goal) | MCL (Allowable Level) | Major Sources in Drinking Water |
| Fluoride (North Garland Co.) | N | Average: 0.48 Range: 0.40 – 0.57 | ppm | 4 | 4 | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| Fluoride (CAW) | N | Average: 0.74 Range: 0.55 – 0.83 | | | | |
| Fluoride (Hot Springs Village) | N | Average: 0.59 Range: 0.48 – 0.67 | | | | |
| Nitrate [as Nitrogen] (Hot Springs) | N | 0.11 | ppm | 10 | 10 | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits |
| SYNTHETIC ORGANIC CONTAMINANTS INCLUDING PESTICIDES AND HERBICIDES | | | | | | |
| Contaminant | Violation Y/N | Level Detected | Unit | MCLG (Public Health Goal) | MCL (Allowable Level) | Major Sources in Drinking Water |
| Benzo(a)pyrene [PAH] (CAW) | N | 0.03 | ppt | 0 | 200 | Leaching from linings of water storage tanks and distribution lines |
| LEAD AND COPPER TAP MONITORING | | | | | | |
| Contaminant | Number of Sites over Action Level | 90 th Percentile Result | Unit | Action Level | Major Sources in Drinking Water | |
| Lead (Paron Owensville) | 0 | <0.003 | ppm | 0.015 | Corrosion from household plumbing systems; erosion of natural deposits | |
| Copper (Paron Owensville) | 0 | 0.52 | ppm | 1.3 | | |
| <ul style="list-style-type: none"> We are currently on a reduced monitoring schedule and required to sample once every three years for lead and copper at the customers' taps. The results above are from our last monitoring period in 2013. Our next required monitoring period is in 2016. | | | | | | |
| TOTAL ORGANIC CARBON | | | | | | |
| <ul style="list-style-type: none"> The percentage of Total Organic Carbon (TOC) removal was routinely monitored by North Garland County, CAW, City of Hot Springs, and Hot Springs Village in 2015, and all TOC removal requirements set by USEPA were met. TOC has no health effects. However, Total Organic Carbon provides a medium for the formation of disinfection by-products. These by-products include trihalomethanes (THMs) and haloacetic acids (HAAs). | | | | | | |
| REGULATED DISINFECTANTS | | | | | | |
| Disinfectant | Violation Y/N | Level Detected | Unit | MRDLG (Public Health Goal) | MRDL (Allowable Level) | Major Sources in Drinking Water |
| Chlorine (Paron Owensville) | N | Average: 0.66 Range: 0.03 – 2.2 | ppm | 4 | 4 | Water additive used to control microbes |
| BY-PRODUCTS OF DRINKING WATER DISINFECTION | | | | | | |
| Contaminant | Violation Y/N | Level Detected | Unit | MCLG (Public Health Goal) | MCL (Allowable Level) | |
| HAA5 [Haloacetic Acids] (Paron Owensville) | Y | Highest Average: 60 Range: 0 - 103 | ppb | 0 | 60 | |
| TTHM [Total Trihalomethanes] (Paron Owensville) | Y | Highest Average: 136 Range: 81.8 - 185 | ppb | NA | 80 | |
| <ul style="list-style-type: none"> Some people who drink water containing Trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer. Some people who drink water containing Haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer. | | | | | | |
| UNREGULATED CONTAMINANTS | | | | | | |
| Contaminant | Level Detected | Unit | MCLG (Public Health Goal) | Major Sources in Drinking Water | | |
| Chloroform (Paron Owensville) | Average: 74 Range: 39.1 - 129 | ppb | 70 | By-products of drinking water disinfection | | |
| Chloroform (North Garland Co.) | 10.3 | | | | | |
| Chloroform (CAW) | Average: 21.7 Range: 11.5 – 31.9 | | | | | |
| Chloroform (Hot Springs Village) | 10.8 | | | | | |
| Chloroform (Hot Springs) | Average: 17.5 Range: 12.9 – 22.1 | | | | | |
| Bromodichloromethane (Paron Owensville) | Average: 2.62 Range: 1.67 – 3.32 | | 0 | | | |
| Bromodichloromethane (North Garland Co.) | 3.36 | | | | | |
| Bromodichloromethane (CAW) | Average: 4.39 Range: 2.45 – 6.33 | | | | | |
| Bromodichloromethane (Hot Springs) | Average: 2.76 Range: 2.29 – 3.22 | | | | | |
| Bromodichloromethane (Hot Spring Village) | 2.47 | | | | | |
| Dibromochloromethane (CAW) | 0.94 | | 60 | | | |
| Chlorate (CAW) | Average: 206.2 Range: 102 - 358 | ppb | none | By-product of drinking water chlorination | | |

| UNREGULATED CONTAMINANTS > Continued | | | | |
|--|--|-------------|--------------------------------------|---|
| Contaminant | Level Detected | Unit | MCLG (Public Health Goal) | Major Sources in Drinking Water |
| Strontium (UCMR3) (CAW) | Average: 11.81 Range: 6.6 – 15.7 | ppb | Undetermined | Naturally-occurring element; historically, commercial use of strontium has been in the faceplate glass of cathode-ray tube televisions to block x-ray emissions |
| Strontium (UCMR3) (Hot Spring Village) | Average: 43.0 Range: 40.3 – 47.2 | | | |
| Vanadium (UCMR3) (CAW) | Average: 0.48 Range: 0.38 – 0.56 | ppb | Undetermined | Naturally-occurring elemental metal; used as vanadium pentoxide which is a chemical intermediate and a catalyst |
| Vanadium (UCMR3) (Hot Spring Village) | 0.21 | | | |
| Chromium (UCMR3) (CAW) | Average: 0.22 Range: 0.20 – 0.25 | ppb | Undetermined | Naturally-occurring element; used in making steel and other alloys; chromium-3 or -6 forms are used for chrome plating, dyes and pigments, leather tanning, and wood preservation |
| Chromium-6 (UCMR3) (CAW) | Average: 0.065 Range: 0.041 – 0.104 | | | |
| Chromium-6 (UCMR3) (Hot Spring Village) | Average: 0.058 Range: 0.037 – 0.079 | | | |
| <p>♦ Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. MCLs (Maximum Contaminant Levels) and MCLGs (Maximum Contaminant Level Goals) have not been established for all unregulated contaminants.</p> | | | | |

| VIOLATIONS – Paron Owensville Water | | | |
|---|--------------|------------|--|
| TYPE: By-Products | FROM: | TO: | CORRECTIVE ACTION: |
| Exceeded the Maximum Contaminant Level (MCL) for the 12 month running annual average for Trihalomethanes (exceeded 80 ppb in the spring though winter quarter of 2015) | 4/1/2015 | 12/31/2015 | Reviewing disinfection procedures and working on a solution to lower the levels of disinfection by-products in the distribution system |
| Exceeded the Maximum Contaminant Level (MCL) for the 12 month running annual average for Haloacetic Acids (exceeded 60 ppb in the summer quarter of 2015) | 7/1/2015 | 9/30/2015 | Reviewing disinfection procedures and working on a solution to lower the levels of disinfection by-products in the distribution system |
| TYPE: Public Notice Violation | | | |
| Public Education –Failed to provide Public Education Notice regarding elevated THM levels | 9/1/2015 | Current | No action taken as of this report date |
| Public Education –Failed to provide Public Education Notice regarding elevated THM levels | 12/1/2015 | 2/10/2016 | Made notice available to the public with regard to elevated THM levels. |

This institution is an equal opportunity provider and employer.